

# **STARLOG**

## **Macro Tester**

**Model 7805**

### **Copyright Notice**

Copyright ©Unidata Australia 1992. All rights reserved. No part of this publication may be reproduced, transmitted, transcribed, stored in a retrieval system, or translated into any language or computer language, in any form or by any means, electronic, mechanical, magnetic, optical, chemical, manual or otherwise, without prior written permission of Unidata Australia, 3 Whyalla Street, Willetton, Western Australia, 6155, Australia.

Published by Lynn MacLaren Publishing

Printed in Australia.

IBM® is a registered trademark of International Business Machines Corp.

# Table of Contents

<b>1. INTRODUCTION</b>	<b>1</b>
<b>2. OPERATION</b>	<b>2</b>
2.1. ANALOG CHANNELS .....	.2
2.2. COUNTER CHANNELS .....	.2
2.3. SERIAL CHANNELS .....	.2
2.4. CONTROL OUTPUTS .....	.2
2.5. USER POWER SOURCES (UPS) .....	.3



## **1. INTRODUCTION**

The STARLOG MACRO Tester (model 7805A) is a simple, low cost device designed to check the MACRO Data Logger's inputs.

## 2. OPERATION

The tester checks all input channels and output voltages for instrument power in the following manner:

### 2.1. ANALOG CHANNELS

A calibration signal is applied to all 16 analog channels. Analog channel readings should increment by approximately 200 each successive channel. For example: A0 = 200, A1 = 400, A2 = 600, etc.

A0	200
A1	400
A2	600
...	...

### 2.2. COUNTER CHANNELS

Each of the four counter channels is sent a pulse each logger scan.

### 2.3. SERIAL CHANNELS

The Clock Output is wired back into the Data Input of each serial channel (HSIO 0 and HSIO 1). When in Diagnostic Mode, pressing V will test the serial channels. The following responses are possible:

00	serial lines OK
01	serial 0 faulty
10	serial 1 faulty
11	serial 0 and 1 faulty

### 2.4. CONTROL OUTPUTS

The status of the Control Output is visible by means of an LED for each Output (OUT0 and OUT1). When in Diagnostic Mode, pressing V will test the control outputs. If operating correctly, the flash alternately. (Available using firmware version 33 and upwards.)

## **2.5. USER POWER SOURCES (UPS)**

Each UPS voltage (5V, 10V, -12V and + 12V) has a corresponding LED. When the LED is on, so is the voltage. When the LED is off, the UPS is off.

In Diagnostic Mode, the P, 0 and F commands can be used to turn the User Power Supplies On or Off.

This page intentionally left blank.